

PROPOSED SUPPLY, DELIVERY AND INSTALLATION OF 2NO. PLASTIC TANK AT  
NTSA OFFICES - INDUSTRIAL AREA, LIKONI ROAD

ITEM	DESCRIPTION	QTY	UNIT	RATE	AMOUNT (KSH/CTS)
	<b>Note: the outlet to the sanitary appliances shall be at 1000mm above the outlet to the pump</b>				
A.	Supply a PVC reservoir tank of capacity 10,000 litres diameter 2360mm by 2660 height as "KENTANK" CC1000 or equivalent and approved on a 2.5M diameter c/w perforations for connecting 25mm diameter to the pump, 20mm inlet and 25mm over flow. The tank shall have a 32mm 300mm long wash G.I pipe c/w gate valve as pegglar.	2	No		
B.	Provisional sum for construction of 600mm high masonry and BRC reinforced plinth from the ground. The finish to be very smooth. for the two(2no.) tanks	2	Item		
C.	50mm diameter ball valve	2	No.		
D.	Gate valve 1"	3	No.		
E.	Gate valve 1 1/4"	4	No.		
F.	50mm diameter GMS pipe	16	LM		
G.	65mm diameter GMS Pipes	10	LM		
H.	100mm Diameter GMS Pipes	20	LM		
	<b>STERILIZATION</b>				
I.	Allow for sterilization including flushing out water and chlorine to the satisfaction of the Engineer	Item	Item		
	<b>TESTING AND COMMISSIONING</b>				
J.	Allow for setting to work, testing and commissioning of the whole system to the satisfaction of the Engineer	Item	Item		
K.	<b>SUB- TOTAL</b>				
	<b>ADD 16% V. A. T.</b>				
	<b>Total carried to collection page</b>				

21/2/2019.



Telephone: +254-(020) 0206632000  
Email: info@ntsa.go.ke  
website: www.ntsago.ke

# National Transport and Safety Authority

Upper Hill Road  
Upper Hill Plaza  
5<sup>th</sup> Floor  
P.O. Box 3602 - 00506  
Nairobi, Kenya

NTSA/RFQ-238/2018-2019

8<sup>th</sup> May, 2019

To: All prospective candidates,

**RE: CLARIFICATION ON QUOTATION FOR SUPPLY DELIVERY AND  
INSTALLATION OF PLASTIC WATER TANKS AT MOTOR VEHICLE INSPECTION  
CENTRE LIKONI ROAD. ADDENDUM NO.1**

We wish to make the following clarifications:

NO.	ITEM DESCRIPTION
1.	Bills of Quantities (BQs) that were initially omitted have been attached to the bidding document.
2.	As a result of item no. 1 above, the quotation closing date has been extended from Friday 10 <sup>th</sup> May, 2019 10:00a.m to <b>Thursday 16<sup>th</sup> May, 2019 at 10:00a.m.</b>

This addenda forms part of the bidding document and is binding to all bidders. All other terms and conditions of the quotation remain the same.

Bidders who already obtained a copy of the bidding document by downloading from our website are required to acknowledge receipt of this addenda by writing to the undersigned on our email at [procurement@ntsa.go.ke](mailto:procurement@ntsa.go.ke).

Yours sincerely,

Shalakha Shem  
**FOR: DIRECTOR GENERAL**